

TT14-MW02

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 105260

Permit No.

Basin 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54761

1. OWNER DEPT OF NAVY, NAS FALLON ADDRESS AT WELL LOCATION 4755 Pastore Rd  
MAILING ADDRESS 4755 Pastore Rd Fallon, NV, 89496

Subdivision Name: NAS FALLON County: Churchill

2. LOCATION SE 1/4 SW 1/4 Sec 23 T 18 N R 29 E Latitude 39.403848 UTM E 1150353491 NAD 27  
PERMIT/WAIVER No. IEP Longitude 118.700642 NAD 27 N 4302964 NAD 83/WGS 84

Issued by Water Resources

Parcel No. 006-611-01

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Other Auger

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
SILT		0'	4'	4'
SAND		4'	6'	2'
CLAY		6'	7'	1'
SILT		7'	8'	1'
SAND		8'	14'	6'
CLAY		14'	18'	4'

9. WELL CONSTRUCTION			
Depth Drilled	Feet	Depth Cased	Feet
18'		18'	

HOLE DIAMETER (BIT SIZE)			
	From	To	
8	0'	18'	Feet
			Feet
			Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch-40	0'	18'

Perforations:  
Type of perforation Manufactured Slotted  
Size of perforation .010  
From 3' feet to 18' feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0' to 1'  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 2 1/4' to 18'  Pumped  Poured  
Type: 2/16 sand  
Bentonite Chips:  Yes  No 7' to 25'  Pumped  Poured  
Type: 3/8 Bentonite chips

Date started: 11-11-07, 20  
Date completed: 11-11-07, 20

7. Water Level  
Static water level: 7' feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name: Gregg Drilling Contractor  
Address: 950 Howe Rd Contractor  
Martinez, CA 94553  
Nevada contractor's license number issued by the State Contractor's Board: 123-0038113  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: M-2328  
Signed: \_\_\_\_\_  
Date: 11-10-07