STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105290
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59638

1. OWNER Cory Willey
MAILING ADDRESS 5850 Bird Lane Winnemucca Nv 89445

ADDRESS AT WELL LOCATION 5850 Bird Lane Winnemucca NV 89445
Subdivision Name: J.B. Estates County: Humboldt

2. LOCATION SE ¼ ~~SW~~ ¼ Sec 2 T 35N N/S R 37 E
PERMIT/WAIVER No. 5E ~~040-000-48~~
Issued by Water Resources APN 013-03433 Parcel No.

Latitude 40.930856 UTM E 434509 ☒ NAD 27
Longitude 117.777877 N 4531161 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	25	25
Sand and Gravel	x	25	85	60
Gravel and Clay	x	85	125	40
Gravel	x	125	185	60
Gravel and Clay	x	185	220	35

Date started: 15-Oct , 20 07
Date completed: 20-Oct , 20 07

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.625	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.188	+2	220

Perforations:
Type of perforation punched
Size of perforation 1.25 x 0.188
From 180 feet to 220 ~~240~~ feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 4 to 52 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 52 to 220 ☐ Pumped ☒ Poured
Type: 3/8 minus
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 55 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling & Pump Service
Contractor
Address 3040 Callahan St
Contractor
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 0020578
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2208
Signed [signature]
By driller performing actual drilling on site of contractor
Date 11-25-07

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY