N 38.449722 W118.988611 NAD27

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105295
Permit No.
Basin 109

NOTICE OF INTENT NO. 55944

1. OWNER USDA/FOREST SERVICE
MAILING ADDRESS HC 62 BOX 1000 BRIDGEPORT CA 93517
ADDRESS AT WELL LOCATION TUTTLE Well EAST Walker Mining District

2. LOCATION NE ¼ SW ¼ Sec. 20 T. 7 N/S R. 27 E. LYON County
PERMIT NO. R566 (Issued by Water Resources) N/A (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
(1) pull pump + pipe + wire				
(2) TRY TO PULL casing (NO GO)				
(3) Install mills knife to 60' perf. pipe as per waiver # R566 every 1" @ 4 cuts per interval				
(4) Install tremie pipe to bottom mix Bentonite grout + pump to 60' BGS				
(5) DAY 2 measure grout to 65'				
(6) run tremie pipe mix neat cement + pump to surface				
(7) cut casing Below grade				
(8) wait quite some time untill grout stops settling top off w/neat cement				

Date started 11.15.07
Date completed 11.16.07

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2007 DEC -5 AM 10:47

8. ~~WELL CONSTRUCTION~~
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)
From To
Inches ____ Feet ____ Feet
Inches ____ Feet ____ Feet
Inches ____ Feet ____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations: * ORIGINAL LOG # 22705
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 130 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature — °F Quality —

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling + Pump LLC (Contractor)
Address 3540 Green Acres Dr (Contractor)
Carson City NV 89705
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John G Leisch (By driller performing actual drilling on site or contractor)
Date 11.26.07

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627