STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105299
Permit No.
Basin 059

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Well #1

NOTICE OF INTENT NO. 59187

1. OWNER Robert E. Sundquist
MAILING ADDRESS 1774 17Th Ave N.
Lake Worth FL 33460

ADDRESS AT WELL LOCATION 1315 3300 EAST ST.
BATTLE MTN., NV 89820
Subdivision Name: County: Lander

2. LOCATION SE ¼ SW ¼ Sec 31 T 32 N/S R 46 E
PERMIT/WAIVER No. 11-260-04 Issued by Water Resources
Parcel No.

Latitude 40.600442
Longitude 116.833600
UTM E 514079 ☒ NAD 27
N 4494206 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Hard Yellow Clay		5	20	15
Sandy Brown Clay		20	120	100
Sand + Gravel Brown Clay		120	140	20

Date started: 10-23 , 20 07
Date completed: 10-25 , 20 07

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	140

Perforations:
Type of perforation Sawed
Size of perforation 3/16 x 3
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 5 to 60 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥80% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 95 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 60 to 95 ☐ Pumped ☒ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	UNK	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name L B J. Drilling Co. Contractor
Address P.O. Box 902 Contractor
Wnca NV 89446
Nevada contractor's license number 9605
issued by the *State Contractor's Board*
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed By driller performing actual drilling on site or contractor
Date 10-25-07

(Rev 06-08)

USE ADDITIONAL SHEETS IF NECESSARY