

Corrected

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 105316
Permit No. _____
Basin 109

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60802

1. OWNER Washoe Tribe Of Nv And Ca - Carson City
MAILING ADDRESS 919 Highway 395 South Gardnerville,
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 919 Highway 395 South
Stewart, NV 89701

2. LOCATION NW 1/4 SE 1/4 Sec 32 T 15 R 20
PERMIT NO Parcel No.

Latitude 39.11773 Longitude -119.7586 WGS 84
Subdivision Name County Carson City

3. WORK PERFORMED
New Well

4. PROPOSED USE
Community

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Sand		0	8	8
Brown Sand		8	45	37
Brown W/Clay Sand		45	60	15
Brown Sand		60	75	15
Brown W/Clay Sand		75	130	55
Brown Sand		130	190	60
Gray W/Clay Sand		190	205	15
Brown Sand		205	250	45
Brown Sand		250	270	20
Brown Clay		270	276	6
Gray W/Sand Clay		276	284	8
Sand	X	284	346	62

8. WELL CONSTRUCTION

Depth Drilled 346 Depth Cased 343 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
14.8 Inches	0 Feet	346 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
8.58	22.36	0.25	0	300
8.58	22.36	0.25	340	343

Perforations:

Type perforation Johnson Free-Flt
Size perforation 0.04
From 300 feet to 340 feet

N 39.117832
W 119.757601 NAD27

Surface Seal Yes No

Seal Type:

Depth of Seal 200

Neat cement

Placement Method: Pumped

Gravel Packed: Yes No

From 200 feet to 340 Feet

9. WATER LEVEL

Static Water Level 45 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road
Fallon, NV 89407

Contracto

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resource, the on-site driller

Signe [Signature]
By driller performing the actual drilling on site or contract

Date 1/28/2008

Date started 12/19/2007

Date completed 1/11/2008

7. WELL TEST DATA

TEST METHOD Test Pump

Comments	GPM	Drawdown	Time (Hours)
	90	118	24

STATE ENGINEER'S OFFICE
2008 FEB -4 PM 1:28

Install 30% Bentonite from 105' to 200'. Pumped 15.6% Neat Cement from 105' to surface.