STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105325
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59457

1. OWNER John Dedolph
MAILING ADDRESS P.O. Box 281210
Lamoille, NV 89828 83N

ADDRESS AT WELL LOCATION Hog Tommy Rd 2052
Subdivision Name: County: Elko

2. LOCATION SE ¼ ¼ ¼ Sec 24 T N/S R 57 E
PERMIT/WAIVER No. NW 089-001-014
Issued by Water Resources Parcel No.

Latitude 40.73067N
Longitude 115.50015W
UTM E N NAD-83
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loam		0	4	4
Cemented Gravel		4	120	116
Loose Gravel	X	120	122	2
Brown Clay		122	143	11
Sand & Gravel	X	143	155	12

N 40.730761
W 115.499249 NAD27

Date started: 4-Mar, 20 07
Date completed: 6-Mar, 20 07

7. Water Level
Static water level: 78 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	70		5.5

STATE ENGINEERS OFFICE
2007 MAY -1 AM 10:49
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	121.92	188	+2	15
6	SDR-17	PVC	15	155

Perforations:
Type of perforation Screen
Size of perforation 0.032
From 135 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 15 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 52 to 155 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☒ Yes ☐ No 14.5 to 52 ☐ Pumped ☒ Poured
Type: 3/8 Kiwk Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site or contractor)
Date 4-27-07

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY