WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 1053366
Permit No.
Basin 129

NOTICE OF INTENT No. ~~60037~~ 60059

1. OWNER Coeur Rochester
MAILING ADDRESS PO Box 1057
Lovelock NV 89419

ADDRESS AT WELL LOCATION 40 16 50.03 944
118 08 39.875 28 NAD83

2. LOCATION NE ¼ NW ¼ Sec. 22 T. 28 N/S R. 34 E. Pershing County
PERMIT NO. NEV 005-0037 Issued by Water Resources | 088-010-71 Parcel No. | MW 45 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brn weathered Rhyolite, Limstone		0	180	
Brn Rhyolite Fractured		180	430	
Brn Rhyolite Fractured wet 1st water	✓	430	465	
Brown Rhyolite wet 26 gpm	~~465~~	465	490	
Gray Rhyolite Fractured wet	490	525		
N 40.280671 W 118.143435 NAD27				

Date started 6-5, 2007
Date completed 6-10, 2007

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	
2-3	8	

8. WELL CONSTRUCTION
Depth Drilled 525 Feet Depth Cased 523 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 5/8 Inches		0 Feet	5 Feet
8 1/2 Inches		5 Feet	525 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 80	+2	473

Perforations:
Type perforation Slots
Size perforation 020
From 473 feet to 523 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 465
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 465 feet to 525 feet

9. WATER LEVEL
Static water level 495.15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC
Contractor
Address PO Box 141
Contractor
Zamora CA 95698
Nevada contractor's license number issued by the State Contractor's Board 12852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 9111
Signed Jim Whatley
By driller performing actual drilling on site or contractor
Date 2-21-08

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627