

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60033

1. OWNER Coeur Rochester ADDRESS AT WELL LOCATION 40.16 56.42 850
 MAILING ADDRESS PO Box 1057 118 08 34.24 779
Have lock NV 89419 NS R. 34 E Peisading County
 2. LOCATION NW 1/4 NE 1/4 Sec. 22 T 20 NW 44 Subdivision Name
 PERMIT NO. 6050037 088-010 71 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill materials		0	85	
light brown		85	145	
Rhyolite sand quartz				
limestone, frag				
lt. brn rhy. lim		145	230	
Iron				
lt grey to brn	<input checked="" type="checkbox"/>	230	270	
Rhy limestone				
grey to brn rhy		270	380	
quartz limestone				
brn & lt grey		380	390	
Rhyolite block				
brn rhy. sand quartz		390	430	
Silt fractured				
brn sand,	<input checked="" type="checkbox"/>	430	465	
Rhy. limestone				
Silt fractured				
brn sand & rhy.	<input checked="" type="checkbox"/>	465	485	
limestone matrix				
SAME		485	520	

8. WELL CONSTRUCTION
 Depth Drilled 520 Feet Depth Cased 504 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>9 5/8</u>	0	65
<u>8 1/2</u>	65	520

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>5/16</u>	<u>80</u>	<u>454</u>

Perforations:
 Type perforation 510ts
 Size perforation 020
 From 454 feet to 504 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 409
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 411 feet to 520 feet

Date started 6-10, 2007
 Date completed 6-13, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>2-3</u>	<u>001270105-2110072</u>	

9. WATER LEVEL
 Static water level 477.37 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WDL Contractor
 Address PO Box 141 Contractor
Zamora CA 95678
 Nevada contractor's license number 12853
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111
 Signed Jan Whitley
 By driller performing actual drilling on site or contractor
 Date 2-21-08