STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 105405
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57198-37

1. OWNE A & K Earthmovers, Inc.
MAILING ADDRES P.o. Box 1059 Fallon, NV 89407
Fallon, NV 89407

ADDRESS AT WELL LOCATION Pine Rd.
Fallon, NV 89406

2. LOCATION SE 1/4 NW 1/4 Sec 35 T 19 R 28
PERMIT NO DEW-61 Parcel No. ~~008-391-34~~

Latitude 39.46784 Longitude -118.8104 [X] WGS 84
Subdivision Name County Churchill

3. WORK PERFORMED	4. PROPOSED USE	5. WELL TYPE
New Well	Dewatering	Rotary-mud

6. LITHOLOGIC LOG

Materlal	Water Strata	From	To	Thick-ness
Brown Sand	X	0	40	40

N 39.467940
W 118.809423 NAD27

8. WELL CONSTRUCTION
Depth Drilled 40 Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
20 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
8	8.76	0.508	0	40

Perforations:
Type perforation Mills Knife
Size perforation 0.032
From 37 feet to 40 feet

Surface Sea [✓] Ye [ ] No
Depth of Seal 3
Placement Method: Pumped
Gravel Packed: [✓] Ye [ ] No
From 3 feet to 40 Feet

Seal Type:
Concrete Grout

9. WATER LEVEL
Static Water Level 8 feet below land surfac
Artesian Flow G.P.M. P.S.I.
Water temperature ° F Qualit unknown

Date started 7/28/2006
Date completed 7/28/2006

7. **WELL TEST DATA**
TEST METHOD

Comments	GPM	Drawdown	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contracto
Address 403 McLean Road
Fallon, NV 89407
Contracto
Nevada contractor's license number issued by the State Contractor's 29064
Nevada driller's license number issued by the Division of Water Resource, the on-site driller 2307
Signe
By driller performing the actual drilling on site or contract
Date 8/21/2006

RECEIVED
2006 AUG 24 AM 11:31
STATE ENGINEERS OFFICE