WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105432
Permit No.
Basin 105

NOTICE OF INTENT NO. 54157

1. OWNER DA Development
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1200 Golden Eagle Ct. Gardnerville NV

2. LOCATION SW ¼ SW ¼ Sec. 1 T. 12 N/S R. 20 E. Douglas Co County
PERMIT NO. Issued by Water Resources | Parcel No. 1220-01-002-063 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt.		0	11'	11'
Cobbles & Clay		11	31	20'
Brown Clay		31'	97'	66
Clay Cobbles & Gravel		97	210	113'
Gravel & Sand	✓	210'	240	30'
N 38.926282				
W 119.692539 NAD27				
~~38° 53.571 N~~				
~~GPS: 38° 53.571 N~~				
~~119° 41.610 W~~				
Map Datum:				
NAD GPS: WGS 84				
38° 55.571 N				
119° 41.612 W				

Date started Aug 10/06, 20
Date completed Aug 15/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25 6pm.	2	Hrs

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 241' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	240' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	188	+1	20'
6 5/8	PVC	SDR 21	20	240'

Perforations:
Type perforation Sawed
Size perforation 1/8 X 4"
From feet to feet
From 200' feet to 240' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 240' feet

9. WATER LEVEL
Static water level 100' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc. Contractor
Address P.O. Box 599 Contractor
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed Nathaniel L Leach
By driller performing actual drilling on site or contractor
Date Sept 2/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627