WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105438
Permit No.
Basin 179

NOTICE OF INTENT NO. 51412

1. OWNER Jim Hollingsworth
MAILING ADDRESS POB 150806
Ely, NV 89315

ADDRESS AT WELL LOCATION 3010 N. 4th E St.
Latitude N 39° 20' 32.8" NAD83
Longitude W 114° 51' 31.4" Elev. 6,151

2. LOCATION ~~NE~~ SW ¼ ~~SW~~ NW ¼ Sec. 14 T 17 N/S R 63 E White Pine County
PERMIT NO. Issued by Water Resources | APN 005-581-10 Parcel No. 9 | Cross Timbers Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Gravel & Sand		5	10	5
Gravel & Clay		10	15	5
Gravel & Sand		15	70	55
Water Bearing Sands	x	70		
Gravel			95	25
Clay & Gravel		95	105	10
Water Bearing Sands	x	105		
& Gravel			120	15
Clay & Gravel		120	140	20
Clay		140	162	22

N 39.342511
W 114.857858 NAD27

RECEIVED 2006 DEC 18 AM 11:24 STATE ENGINEERS OFFICE

Date started November 14, 2006
Date complated November 22, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120	96	1

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	162 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	162

Perforations:
Type perforation Factory
Size perforation 1/8" x 2 1/2" 6 Rows
From 82 feet to 162 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 Feet
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 162 feet

9. WATER LEVEL
Static water level 64 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. Contractor
Address 557 Ely Ave. Contractor
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed Rich Lewis By Jerald D. Christiansen
By driller performing actual drilling on site or contractor
Date November 27, 2006

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627