

MW 12

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105475
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34941

1. OWNER COUNTY OF CLARK ADDRESS AT WELL LOCATION 389 CONVENTION
MAILING ADDRESS 5005 GRAND CENTRAL CENTER DR
Las Vegas NV 89115 Subdivision Name: County: CLARK

2. LOCATION SE 1/4 Sec 9 T 21 N R 61 E Latitude 36° 09' 02" UTM E NAD 27
PERMIT/WAIVER No. 162-09-703-013 Longitude 115° 09' 34" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other
4. PROPOSED USE
 Domestic Irrigation Test Monitor
 Municipal/Industrial Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other H.S.P.
6. LITHOLOGIC LOG
Material Water Strata From To Thickness
ASPHALT 0 3" 3"
CLAYEY SAND GRAVEL 3" 6.6" 6.3"
CALICHE 6.6" 8" 1.6"
SANDY CLAY 8" 14" 6"
CLAYEY SAND 14" 16" 2"
CLAYEY GRAVEL 16" 22.6" 6.6"
SANDY CLAY 22.6" 29" 6.6"
CLAYEY GRAVEL 29" 30" 1"
CALICHE 30" 34" 4"

9. WELL CONSTRUCTION
Depth Drilled 34' Feet Depth Cased 34' Feet
HOLE DIAMETER (BIT SIZE)
From 0" To 34' Feet
Inches 0" Feet 34' Feet
Inches Feet Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
2" PVC SCA40 0 34

Perforations:
Type of perforation SLOTTED SLRIECH
Size of perforation 0.020
From 19' feet to 34' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Annular Seal: Yes No
 Neat Cement to Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout 0" to 2" Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 17' to 34' Pumped Poured
Type: 12 SILVER SAND
Bentonite Chips: Yes No 2' to 17' Pumped Poured
Type: 3/8 HOLE PLUG BAROLD

7. Water Level
Static water level: 22.50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

DCNR/DWR
RECEIVED
MAY 19 2008

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name TIMOTHY THOMPSON Contractor
Address 750 PLOT ROAD SUITE Las Vegas NV 89119 Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2097
Signed [Signature] By driller performing actual drilling on site or contractor
Date