WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105481
Permit No.
Basin 212

NOTICE OF INTENT NO. 33527

1. OWNER PUBLIC RIGHT OF WAY
MAILING ADDRESS 500 S. GRAND CENTRAL PARKWAY LV, NV. 89155
ADDRESS AT WELL LOCATION PARADICE AT CONVENTION CENTER LV. NV.

2. LOCATION SE ¼ SE ¼ Sec. 9 T. 21 N/S R. 61 E/W CLARK County
PERMIT NO. Issued by Water Resources | Parcel No. 16210499004 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0'	.5'	.5'
STONE + SAND BASE		.5'	1.5'	1.0'
SILT + SAND		1.5'	4.5'	3.0'
CALICHE		4.5'	6.5'	2.0'
SILTY CLAY		6.5'	16.5'	10.0'
CALICHE		16.5'	19.5'	3.0'
SILTY SANDY CLAY		19.5'	30.5'	11.0'
CALICHE + GRAVEL	YES	30.5'	32.5'	2.0'
SILTY SAND + GRAVEL	YES	32.5'	35.0	2.5'

FACILITY ID NUMBER
8-000-841-6

MAP DATAM
WGS 84

36°07 57.70 N
115° 09 16.80 W

Date started 5-15, 2008
Date completed 5-16, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR RECEIVED MAY 23 2008 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.5 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	35

Perforations:
Type perforation MACHINE SLOT
Size perforation .010
From 20 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 18'
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 18' feet to 35' feet

9. WATER LEVEL
Static water level 23.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING SERVICES LLC. (Contractor)
Address 7150 PLACID ST LV. NV. 89119 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 5-23-2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627