WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
003813

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105576
Permit No.
Basin 212

NOTICE OF INTENT NO. 33531

1. OWNER Seller Sandra Ragsdale Tr & Schumacher Colleen K Tr
MAILING ADDRESS P.O. Box 5015
Buena Park, CA. 90622-5015
ADDRESS AT WELL LOCATION 333 E. Charleston Blvd
Las Vegas, NV

2. LOCATION SW ¼ SW ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. Issued by Water Resources | 139-34-410-137 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	.3	.3
Silty Clay		.3	8	7.7
Calicut		8	10	2
Clay		10	12	2
Silty Clay	13	12	16	4
Clay		16	22	6
Silty Clay w/Gravel		22	36	14

MAP DATUM WGS 84
PEW-3 36°09.535N 115°08.951W

FACILITY ID #
8-001049

Date started 5/29, 2008
Date completed 5/29, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 36 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11½ Inches	0 Feet	36 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		Sch 40 PVC	35	6

Perforations:
Type perforation Machine Slot
Size perforation .020
From 35 feet to 10 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 8'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 36 feet to 8 feet

9. WATER LEVEL
Static water level 13 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC
Contractor
Address 7150 Placid St
Contractor
Las Vegas NV 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6/09/8

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627