STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105591
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55250

1. OWNER Gail Giusti
MAILING ADDRESS 421 Kittridge
Elko, NV 89801

ADDRESS AT WELL LOCATION 3838 Lupine St
Lot 3, Block 58
Subdivision Name: County: ELKO

2. LOCATION SW ¼ SE ¼ Sec 35 T 35N N/S R 55 E
PERMIT/WAIVER No. 037-058-003
Issued by Water Resources Parcel No.

Latitude Longitude
UTM E N
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SUB SOIL		0	3	3
SAND & GRAVEL		3	7	4
CALICHI CLAY		7	72	65
GRAVEL		72	78	6
CALICHI CLAY		78	195	117
SAND & GRAVEL	X	195	220	25

Date started: 15-Dec, 20 05
Date completed: 19-Dec, 20 05

RECEIVED 2006 AUG 14 AM 11:27 STATE ENGINEERS OFFICE

7. Water Level
Static water level: 174 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	78		2.5

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	18
6	SDR-17		18	220

Perforations:
Type of perforation SCREEN
Size of perforation 0.05
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	0 to	51	☒ Pumped	☒ Poured
☒ ≥30% Bentonite Grout	to		☐ Pumped	☒ Poured

Gravel Pack: ☒ Yes ☐ No 51 to 220 ☐ Pumped ☐ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type: BENTONITE 17-51

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY
Contractor
Address P.O. BOX 525
Contractor
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1584
Signed
By driller performing actual drilling on site or contractor
Date 8-10-06

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

4