

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY

Log No. 105626  
Permit No. \_\_\_\_\_  
Basin 101

TTBW-MW04

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61823

1. OWNER NAS FALLON ADDRESS AT WELL LOCATION 4755 Pasture Rd  
MAILING ADDRESS 4755 Pasture Rd Fallon, NV. 89496  
Fallon, NV. 89496 Subdivision Name: NAS FALLON County: Churchill

2. LOCATION SE 1/4 SW 1/4 Sec 11 T 18 N R 29 E Latitude UTM E 2591180.59  NAD 27  
PERMIT/WAIVER No. TRP Longitude N 14828475.84  NAD 83/WGS 84

Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  
 Municipal/Industrial  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND</u>		<u>0'</u>	<u>10'</u>	<u>10'</u>
<u>CLAYED SAND</u>		<u>10'</u>	<u>11'</u>	<u>1'</u>
<u>SILTY SAND</u>		<u>11'</u>	<u>14'</u>	<u>3'</u>
<u>SILT</u>		<u>14'</u>	<u>16'</u>	<u>2'</u>
<u>CLAY</u>		<u>16'</u>	<u>20'</u>	<u>4'</u>

9. WELL CONSTRUCTION

Depth Drilled 20 1/8 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>8</u> Inches	<u>0</u> Feet	<u>18</u>	
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>SCH. 40</u>	<u>0</u>	<u>18</u>

Perforations:

Type of perforation Manufactured slotted  
Size of perforation .010

From 3 feet to 18 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement 0 to 1  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 2 1/2' to 18'  Pumped  Poured  
Type: 2 1/2' sand

Bentonite Chips:  Yes  No 1' to 2 1/2'  Pumped  Poured  
Type: 3/8 Chips

Date started: 3-20 20 08  
Date completed: 3-20 20 08

7. Water Level  
Static water level: 9' feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Gregg Drilling Contractor  
Address 950 Howe Rd Contractor  
Martinez, CA 94553  
Nevada contractor's license number CA3-0038113  
issued by the State Contractor's Board  
Nevada driller's license number issued by the M-2328  
Division of Water Resources, the on-site driller

Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 3-20-08