STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105707
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33700

1. OWNER T-WHRLLC
MAILING ADDRESS plaza Hotel 1 main Street
Las Vegas NV 89101

ADDRESS AT WELL LOCATION MW-1
900 East Fremont street
Subdivision Name: County: Clark

2. LOCATION NW SE ¼ Sec 34 T 20 N R 61 E
PERMIT/WAIVER No. 139-34-612-059
Issued by Water Resources Parcel No.

Latitude 36° 10231 UTM E ☐ NAD 27
Longitude 115° 08888 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other ☒ (AUGER)

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete		0	8"	
fill w sand and gravel		8"	3'	
Sandy ct Lt gray		3'	9'	
Caliche white		9'	16'	
Sandy clay w caliche	13' wh	16'	19'	
claye sand white		19'	25	

DCNR/DWR
RECEIVED
JUL 08 2008
LAS VEGAS OFFICE

Date started: 6-3, 20 08
Date completed: 6-3, 20 08

7. Water Level
Static water level: 14.8 feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality: good

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	1	24	.5

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	10.79	.237	0	25

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement 1 to 5 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No to ☐ Pumped ☒ Poured
Type: 8-12 Silica sand
Bentonite Chips: ☒ Yes ☐ No 5 to 8 ☐ Pumped ☒ Poured
Type: 3/8 chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057 -T4
Signed [signature]
By driller performing actual drilling on site or contractor
Date 6-27-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY