

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105711
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 594.170 and NAC 594.1840

NOTICE OF INTENT NO. 33700

1. OWNER T-WHRLLC ADDRESS AT WELL LOCATION mw-5
MAILING ADDRESS Plaza Hotel 1 main street 900 East Fremont street
Las Vegas NV 89101 Subdivision Name: _____ County: Clark
2. LOCATION NW 1/4 SE 1/4 Sec 34 T. 20 N. R. 61 E. Latitude 36° 10240 UTM E NAD 83
PERMIT NUMBER 139-34-612-059 Longitude 115° 08892 N NAD 83

3. WORKED PERFORMED New Well Replace Recondition
 Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC
 Air Other (AUGER)

6. LITHOLOGIC LOG

Material	Water Static	From	To	Thick-ness
Asphalt		0	4"	
fill gravelly sand		4"	2.5	
Clay sand Lt gray		2.5	8	
Finesand Lt gray	WL-14.0	8	14	
Caliche		14	17	
Sandy clay Lt gray		17	22	
Caliche		22	23	
Clay sand Lt gray		23	25	

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet
HOLE DIAMETER (INT SIZE)
From 8 Inches To 25 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
4.5 10.74 .237 0 25

Perforations:
Type of perforation Factory Blotted
Size of perforation .020
From 10 feet to 25 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal Yes No
 Neat Cement 1 to 5 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No _____ to _____ Pumped Poured
Type: 8-12 silica sand
Bentonite Chips: Yes No 5 to 8 Pumped Poured
Type: 3/8 chips

7. Water Level
Static water level 14.8 feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: NA °F
Quality: good

8. WELL TEST DATA

TEST METHOD:	<input checked="" type="checkbox"/> Bailor	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailor	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>1</u>	<u>24</u>	<u>.5</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells Contractor
Address 570 Corinthian Way Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the State Contractors Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2057-T4
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 6-27-08

DCNR/DWR RECEIVED
JUL 08 2008
LAS VEGAS OFFICE