

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 105727  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34573

1. OWNER Schwarz, Thomas F. ADDRESS AT WELL LOCATION 251 N. Nellis Blvd  
MAILING ADDRESS 251 N. Nellis Blvd. LV, NV 89110  
LV, NV 89110-5321 Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION NE 1/4 SE 1/4 Sec 32 T 20 N R 62 E Latitude N 36° 09' 57.8" UTM E  NAD 27  
PERMIT/WAIVER No. 140-32-701-005 Longitude W 115° 03' 44.6" N  NAD 83/WGS 84

Issued by Water Resources Parcel No. MW-4

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>2</u>	
<u>clayey sand</u>		<u>2</u>	<u>17</u>	
<u>sand</u>	<u>17</u>	<u>17</u>	<u>20</u>	
<u>clay</u>		<u>20</u>	<u>28</u>	

9. WELL CONSTRUCTION

Depth Drilled 28 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>28</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>28</u>

Perforations:

Type of perforation Factory

Size of perforation .020

From 13 feet to 28' feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout 0 to 7  Pumped  Poured

≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 10 to 28  Pumped  Poured

Type: #3

Bentonite Chips:  Yes  No 7 to 10  Pumped  Poured

Type: Hole plug

Date started: 6/25, 2008

Date completed: 6/25, 2008

7. Water Level

Static water level: 17 feet below land surface

Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: \_\_\_\_\_ °F

Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR RECEIVED

JUL 03 2008

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling, Inc. Contractor

Address 4255 W. Post Rd. Contractor

Las Vegas NV 89118

Nevada contractor's license number 0054931

issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller MW-1869

Signed [Signature]

By driller performing actual drilling on-site or contractor

Date 6/26/08