

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **SPSY9**

1. OWNER Jack Douglas ADDRESS AT WELL LOCATION 1870 Gougar SILVER SPRINGS, NV LYON  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION SW 1/4 SE 1/4 Sec. 19 T. 17 N/S R. 25 E County LYON  
PERMIT NO. 07-442-03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	11	11
SAND-COARSE GRAVEL		11	50	39
GRAY CLAY-SAND		50	58	8
BLACK SANDY GRAVEL		58	148	90
MEDIUM GRAVEL		148	180	32

39.31759°N  
119.21576°W NAD83  
N 39.317691  
W 119.214773 NAD83

8. WELL CONSTRUCTION  
Depth Drilled 180 Feet Depth Cased 180 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 5/8 Inches To 180 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 3/8	13	.188	1	20
6 3/8	4	SDR 21	20	180

Perforations:  
Type perforation GRINDER CUT  
Size perforation 10 4/5" x 4"  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From 160 feet to 180 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 52 FT  Neat Cement  
Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
Gravel Packed:  Yes  No  
From 52 feet to 180 feet

9. WATER LEVEL  
Static water level 36 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality CLEAR

Date started 22 FEB, 2007  
Date completed 23 FEB, 2007

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25+</u>	<u>80:11 AM</u>	<u>1.5</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name BLAIN DRILLING & PUMP CO. INC.  
Address P.O. Box 1255 Carson City, NV 89702  
Nevada contractor's license number issued by the State Contractor's Board 46498  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167  
Signed Jack Watson  
By driller performing actual drilling on site or contractor  
Date 25 FEB 07