STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105903
Permit No.
Basin 066

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61295

1. OWNER Newmont Mining Corporation
MAILING ADDRESS PO Box 388
NE NW Valmy, NV 89435

ADDRESS AT WELL LOCATION Twin Creeks Mine
TMO-80007
Subdivision Name: County: Humboldt

2. LOCATION ~~NW~~ ¼ ~~SW~~ ¼ Sec 8 T 39N N/S R 43 E
PERMIT/WAIVER No. M/O-1464
Issued by Water Resources Parcel No.

Latitude 41.282414
Longitude 117.156273
UTM E 486913.12837 [x] NAD 27
N 4569907.911739 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[x] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	190	190
Bedrock, Sandstone, Limestone		190	900	720

Date started: 22-Feb , 20 08
Date completed: 27-Feb , 20 08

9. WELL CONSTRUCTION
Depth Drilled 900 Feet Depth Cased 900 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 5/8	Inches	0	Feet	20	Feet
6 3/4	Inches	20	Feet	900	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8	PVC	Sch 80	0	900

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 840 feet to 900 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 51 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 839 to 905 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 839 to 51 [ ] Pumped [x] Poured
Type: Med. Hole Plug 3/8" Chip

7. Water Level
Static water level: 503 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: 72 °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150 PSI	40	N/A	2 hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1777
Signed Dennis L. White (By driller performing actual drilling on site or contractor)
Date 3/10/08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY