STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105934
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61907

1. OWNER ANNA GETTE
MAILING ADDRESS P. O. BOX 50365
SPARKS, NV 89435

ADDRESS AT WELL LOCATION 165 DIAMOND AVE
(BLK 8, LOT 12)
Subdivision Name: Last Chance Ranch #11 County: ELKO

2. LOCATION NE ¼ SE ¼ Sec 11 T 34N N/S R 56 E
PERMIT/WAIVER No. 031-008-012
Issued by Water Resources Parcel No.

Latitude 40.847651
Longitude 115.622953
UTM E 11T 0616081 [X] NAD 27
N 4522446 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
SILTSTONE		2	100	98
SILTSTONE W/ GRAVEL MIX	120	100	120	20
BLACK SHALE	220	120	240	120

Date started: 5-Dec, 20 07
Date completed: 5-Dec, 20 07

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1	240

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 120 feet to 140 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 240 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 15 to 50 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 52 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR LIFT	10		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 12/14/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY