STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105944
Permit No.
Basin 045

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62120

1. OWNER MITCH BUZZETTI
MAILING ADDRESS P. O. BOX 281251
LAMOILLE, NV 89828

ADDRESS AT WELL LOCATION 2598 CROSSROAD
LAMOILLE, NV
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION ~~NW~~ SW ¼ NW ¼ Sec 20 T 33N N/S R 57 E
PERMIT/WAIVER No. 007-080-~~045~~ 127
Issued by Water Resources Parcel No.

Latitude 40.732625
Longitude 115.468611
UTM E 11T 0629317 ☒ NAD 27
N 4509993 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
GRAVEL, SAND & BOULDERS		2	40	38
SILTSTONE & GRAVEL MIX		40	90	50
GRAVEL & SAND	XXX	90	120	30

Date started: 9-Jan, 20 08
Date completed: 16-Jan, 20 08

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13.	.188	+1	120

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 5 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 120 ☐ Pumped ☒ Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 50 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 1/23/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY