

N, 38° 47.426 W, 119° 23.560 NAD 83 WGS84

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 105954
Permit No. 107
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60873

1. OWNER Pata Dawn Wescott ADDRESS AT WELL LOCATION 187 Buck Court
MAILING ADDRESS Wellington NV 89444
2. LOCATION SW 1/4 NE 1/4 Sec. 27 T. 11 N. R. 23 E. 240 County Smith Valley
PERMIT NO. 09-257-03 Parcel No. Subdivision Name

3. WORK PERFORMED 251 4. PROPOSED USE Domestic 5. WELL TYPE Rotary
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other Municipal/Industrial Monitor Stock Air Other Hand

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>DB + Sand</u> <u>some clay</u>		<u>0</u>	<u>117</u>	<u>117</u>
<u>Gray Clay</u>		<u>117</u>	<u>120</u>	<u>3</u>
<u>DB, Sandy Clay</u>		<u>120</u>	<u>215</u>	<u>95</u>
<u>Clay - some sand</u>		<u>215</u>	<u>223</u>	<u>8</u>
<u>DB - Solidified Sand</u>		<u>223</u>	<u>307</u>	<u>84</u>
<u>Wet Clay + Sand</u>		<u>307</u>	<u>373</u>	<u>66</u>
<u>DB + Sand</u>		<u>373</u>	<u>395</u>	<u>18</u>
<u>Sandstone</u>		<u>395</u>	<u>420</u>	<u>25</u>

Vertical text on left: 2001 FEB - 7 11:11:28

8. WELL CONSTRUCTION
Depth Drilled 420 Feet Depth Cased 420 Feet
HOLE DIAMETER (BIT SIZE)
From 10 1/4 Inches 0 Feet 60 Feet
8 3/4 Inches 65 Feet 420 Feet
Inches Feet Feet
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 7/8 13 1.88 70 20'
6 3/4 SDR-21 2' 420'
Perforations:
Type perforation 5200 20
Size perforation 1/2 x 3 sidewall
From 360 feet to 420 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal 53 Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From 53 feet to 420 feet

Date started 1-30, 2008
Date completed 2-2, 2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>4 1/2</u>

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Trach Drilling Inc. Contractor
Address P.O. Box 590 Contractor
Silver Spring NV 89429
Nevada contractor's license number 31841
issued by the State Contractor's Board
Nevada driller's license number issued by the 2346
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 2-06-08