

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 105968  
Permit No. \_\_\_\_\_  
Basin 212

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34565

1. OWNER CITY OF NORTH LAS VEGAS ADDRESS AT WELL LOCATION 11039 N. Main St  
MAILING ADDRESS 2206 Civic Center Dr. NORTH LAS VEGAS, NV  
NORTH LAS VEGAS, NV 89030 Subdivision Name: \_\_\_\_\_ County: CLARK

2. LOCATION SE 1/4 SE 1/4 Sec 22 T 20 N R 01 E Latitude N36°11'25.8" UTM E  NAD 27  
PERMIT/WAIVER No. 139-22-812-001 Longitude W115°08'03.7" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. PEW-1

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  Cable  Rotary  RVC  
 Other Auger

6. LITHOLOGIC LOG PEW-1

Material	Water Strata	From	To	Thick-ness
<u>Fill</u>		<u>0</u>	<u>1.5</u>	
<u>Sandy clay</u>		<u>1.5</u>	<u>13</u>	
<u>sand</u>	<u>13</u>	<u>13</u>	<u>15</u>	
<u>clay</u>		<u>15</u>	<u>25</u>	

9. WELL CONSTRUCTION  
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>25</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>25</u>

Perforations:

Type of perforation Factory slot  
Size of perforation .020

From 10 feet to 25 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 6  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 8 to 25  Pumped  Poured  
Type: #3

Bentonite Chips:  Yes  No 6 to 8  Pumped  Poured  
Type: hole plug

Date started: June 3, 20 008  
Date completed: June 3, 20 008

7. Water Level  
Static water level: \_\_\_\_\_ feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Elite Drilling Inc. Contractor  
Address 4255 W. Post Rd. Contractor  
Las Vegas, NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 11-1869  
Division of Water Resources, the on-site driller  
Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 6/25/08