STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105997
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34569

1. OWNER Chetak Development Corporation
MAILING ADDRESS 9901 Covington Cross Dr. #170
Las Vegas, NV 89144-6595

ADDRESS AT WELL LOCATION 2236 Paradise Rd.
Las Vegas, NV 89104
Subdivision Name: County: Clark

2. LOCATION SW ¼ SW ¼ Sec 3 T 21 N or S R 61 E
PERMIT/WAIVER No. 1162-03-411-01
Issued by Water Resources Parcel No.

Latitude 36°08'39.1" Longitude 115°09'18.0"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
Well # MW-12

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphault		0	0.5'	0.5'
Fill		0.5'	2'	1.5'
Sand w/Gravel		2'	5.5'	3.5'
Caliche		5.5'	6.5'	1'
Clay		6.5'	7'	0.5'
Caliche		7'	9'	2'
Sandy Clay		9'	11.5'	2.5'
Caliche		11.5'	12'	0.5'
Sandy Clay	16'	12'	25'	13'

Date started: 6/18, 20 08
Date completed: 6/18, 20 08

7. Water Level
Static water level: 16 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	Sch 40	0	25

Perforations:
Type of perforation Factory Slot
Size of perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout 0 to 4' ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 8' to 25' ☐ Pumped ☒ Poured
Type: #3
Bentonite Chips: ☒ Yes ☐ No 4' to 8' ☐ Pumped ☒ Poured
Type: Hole plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 0054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on-site or contractor)
Date 6/19/08

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627