STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 106118

Permit No.

Basin 089

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61957

1. OWNER Well Fargo Bank Vernon Lee Davis Trust
MAILING ADDRESS 5340 Kietzke Ln. Ste. 200
Reno NV. 89511

ADDRESS AT WELL LOCATION 6190 Franktown Rd.
Washoe Valley
Subdivision Name: County: Washoe

2. LOCATION NW¼NW¼ Sec22T16N/ R19E
PERMIT/WAIVER NO. 76548, 76549 W-620 (Issued by Water Resources) 055-110-32 (Parcel. No.)

Latitude 39.24334 UTM E ☐ NAD 27
Longitude 119.84180 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	20	20
Cobbels		20	30	10
Sand & cobbels		30	50	20
Sand		50	70	20
Sand cobbles brown		70	110	40
Sand Gravel	X	110	170	60
Sand gravel cobbels	X	170	220	50
Weatherd granite		220	225	5

N39.243445
W119.840797 NAD27

Date started: 4/8, 20 08
Date completed: 5/7, 20 08

7. Water Level
Static water level: 14 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: Cool °F
Quality: Not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200	120	152

9. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 225 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	225 Feet
17 1/2 Inches	0 Feet	225 Feet
22 Inches	0 Feet	225 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.38	.250	+2	225

Perforations:
Type of perforation Screen
Size of perforation .050
From 140 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 225 ☐ Pumped ☒ Poured
Type: 1/8 X 1/4
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. (CONTRACTOR)
Address 1600 Mt. Rose Hwy (CONTRACTOR)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on site or contractor
Date 5/22/08

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com