

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
 Log No. 106132
 Permit No. _____
 Basin 108

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

N39.031325
W119.047532

NOTICE OF INTENT NO. 57514

1. OWNER James Perry ADDRESS AT WELL LOCATION 606 Pete Henricks
 MAILING ADDRESS 249 Hwy 95-A North Yerington, Nv 89447
 Subdivision Name: _____ County: Lyon

2. LOCATION N 1/4 SW 1/4 Sec 35 T 14N N/S R 26 E Latitude N.39.03123 UTM E NAD 27
 PERMIT/WAIVER No. 014-372-16 Longitude W.119.04851 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil, sand, gravel & few rock		0	3	3
Sand, gravel, few rock alluvial fill		3	21	18
Sand, gravel, few rock with clay stratas. Alluvial fill		21	64	43
Clay, sand, gravel & few rocks Alluvial fill		64	126	62
Clay, sand, gravel alluvial fill		126	152	26
Coarse sand, gravel alluvial fill	X	152	158	6
Clay & sand alluvial fill		158	165	7
Coarse sand, small gravel alluvial fill	X	165	180	15
Coarse sand, small gravel & clay stratas alluvial fill		180	191	11
Clay & coarse sand alluvial fill		191	197	6
Coarse sand, small gravel clean	X	197	210	13
Coarse sand, small gravel with clay. Alluvial fill	X	210	220	10
Hard brown clay		220	232	12
Coarse sand, gravel & small rock alluvial fill	X	232	240 239	8 7
Adapter PVC/Steel 12" X 280				

Date started: 21-Dec, 2007
 Date completed: 17-Jan, 2008

9. WELL CONSTRUCTION

Depth Drilled 240 ~~239~~ Feet Depth Cased 239 ~~241~~ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
11 1/4	0	50		
10 5/8	50	239		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188 Steel	+2	19
6 5/8	3.63	.260 sch 40 PVC	19	99
6 5/8	4.06	.316 SDR 21 PVC	99	239

Perforations:

Type of perforation Factory Screen
 Size of perforation .032 X 1/4" spacing X 6 rows

From 199 feet to 239 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 0 to 50 Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 50 to 239 Pumped Poured
 Type: 1/4" to 3/8" round well rock

Bentonite Chips: Yes No _____ to _____ Pumped Poured
 Type: _____

7. Water Level

Static water level: 105 feet below land surface
 Artesian Flow: N/A G.P.M. _____ P.S.I. _____
 Water Temperature: COLD °F
 Quality: GOOD

8. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	40	200' Air line	3

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ogden Drilling Contractor
 Address 152 N. Bybee Ln Contractor
Yerington, Nv 89447

Nevada contractor's license number issued by the State Contractor's Board 57011
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634

Signed [Signature]
 Date 3-16-08
 By driller performing actual drilling on site or contractor