

Log No. 106189
 Permit No. 98
 Basin. 98

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59045

1. OWNER Shane Cheency ADDRESS AT WELL LOCATION 5262 Echo Dam Road in Dry Valley
 MAILING ADDRESS PO Box 682 Pioche NV 89043
 2. LOCATION S1E 1/4 SW 1/4 Sec. 36 T. 1 N. R. 68 E. Lincoln County
 PERMIT NO. 6301-40 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand-boulders		0	120	120
Clay-boulders	X	120	160	40
Fossiliferous Rock		160	180	20
Sand-Graavel	X	180	192	12
Hard Rock		192	194	2

WG.S 84
 N 370 53,768'
 W 1740 18,777'

N 3789672
 W 114,31218 NAD27

8. WELL CONSTRUCTION
 Depth Drilled 194 Feet Depth Cased 194 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11 Inches To 0 Feet 194 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>194</u>

Perforations:
 Type perforation saw cut
 Size perforation 1/8" x 30
 From 34 feet to 74 feet
 From 94 feet to 194 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 194 feet

9. WATER LEVEL
 Static water level 126 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89007 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 6-1-08

Date started 5-27-08, 20.....
 Date completed 5-28-08, 20.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>		<u>2</u>