

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33904

1. OWNER CLARK COUNTY SANITATION ADDRESS AT WELL LOCATION INDIAN SPRINGS
 MAILING ADDRESS 5005 GRAND CENTRAL NEVADA
PARKWAY LAS VEGAS NV. 89155

2. LOCATION NE 1/4 NW 1/4 Sec 10 T 16 N/R 56 E CLARK County
 PERMIT NO. 059-10-101-002
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND/CLAY + GRAVEL		0	20	20
SANDY CLAY		20	45	25
CLAY + GRAVEL	X	45	80	35
DRILLED OUT EXISTING 2" PVC + REPLACED WITH 4" PVC.				
MW 2 MAP DATUM WBS 84 36° 34.870 N 115° 38.840 W				

8. WELL CONSTRUCTION
 Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)
 From 11.5 Inches To 0 Feet
0 Feet 80 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>40SLH</u>	<u>0</u>	<u>80</u>

Perforations:
 Type perforation MACHINE SLOT
 Size perforation .020
 From 60 feet to 80 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal 58
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured

Gravel Packed: Yes No
 From 58 feet to 80 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ENGLE DRILLING SERVICES LLC.
 Contractor
 Address 7150 S PLACID ST LAS VEGAS NV
 Contractor 89119

Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
 Signed Neil & Wilkton
 By driller performing actual drilling on site or contractor
 Date 7-25-2008

Date started 7-22, 2008
 Date completed 7-23, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

