

026811
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33906

1. OWNER 02007 ARIZONA CHARLES PROCO ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 85 BROAD ST 740 S. DECATUR BLVD
NY NY 10004-2434 LAS VEGAS NV 89107
 2. LOCATION NW 1/4 SE 1/4 Sec 36 T. 30 N/S R. 60 E CLARK County
 PERMIT NO. 138-36701-022 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other H2A

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SAND & GRAVEL</u>		<u>0</u>	<u>2.5</u>	<u>2.5</u>
<u>CLAY</u>		<u>2.5</u>	<u>7</u>	<u>4.5</u>
<u>SILTY CLAY w/ GRAVEL</u>		<u>7</u>	<u>12.5</u>	<u>5.5</u>
<u>CLAY</u>		<u>12.5</u>	<u>13.5</u>	<u>1</u>
<u>SILTY CLAY w/ GRAVEL</u>		<u>13.5</u>	<u>15.5</u>	<u>2</u>
<u>CLAY</u>		<u>15.5</u>	<u>16.5</u>	<u>1</u>
<u>SILTY CLAY w/ GRAVEL</u>		<u>16.5</u>	<u>25</u>	<u>8.5</u>

MAP DATUM
WGS 84
36° 09.785' N 115° 12.369' W

FACILITY ID #
M-006645

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 1/2 Inches To 6 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>5CM 40PVC</u>	<u>25</u>	<u>0</u>

Perforations:
 Type perforation MACHINING SCOT
 Size perforation 2 1/2
 From 25 feet to 10 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 8
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 25 feet to 8 feet

Date started 8/04, 2008
 Date completed 8/07, 2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

AUG 10 8 2008
 LAS VEGAS OFFICE

9. WATER LEVEL
 Static water level 14.7 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature WARM F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LEAGUE DRILLING SERVICES LLC Contractor
 Address 7150 PLACID ST Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-222
 Signed Matt J...
 By driller performing actual drilling on site or contractor
 Date 8/05/8