

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. _____
 Permit No. _____
 Basin *044*

NOTICE OF INTENT NO. *30538*

1. OWNER *Webber Ranch LLC* ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS *802 Elbert #11* _____
Elko, Nv. 89801 *Devils Gate Ranch*
13 miles N of Elko Exit 317
 2. LOCATION *SE 1/4 SE 1/4 Sec. 35 T. 38* @/S R. *57 E* *Elko* County _____
 PERMIT NO. *70331* Issued by Water Resources Parcel No. *006-57-0003* Subdivision Name _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock _____
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<i>Sand, clay</i>		<i>0</i>	<i>18</i>	<i>18</i>
<i>Clay</i>		<i>18</i>	<i>30</i>	<i>12</i>
<i>sand, gravel</i>	<i>X</i>	<i>30</i>	<i>115</i>	<i>85</i>
<i>Clay</i>		<i>115</i>	<i>141</i>	<i>26</i>
<i>Sand, gravel</i>	<i>X</i>	<i>141</i>	<i>260</i>	<i>119</i>
<i>Sand, & clay</i>		<i>260</i>	<i>285</i>	<i>25</i>
<i>Cemented gravels</i>	<i>X</i>	<i>285</i>	<i>400</i>	<i>115</i>
<i>NAD 27</i>				
<i>41° 07.982 N</i>				
<i>115° 30.617 W</i>				
<i>106366</i>				
<i>2008 AUG 22 PM 12:00</i>				
<i>STATE ENGINEER'S OFFICE</i>				

8. WELL CONSTRUCTION
 Depth Drilled *400* Feet Depth Cased *400* Feet
 HOLE DIAMETER (BIT SIZE)
 From *24* Inches To *0* Feet *400* Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<i>16</i>	<i>62.4</i>	<i>.375</i>	<i>+2</i>	<i>400</i>

Perforations:
 Type perforation *Factory Milled*
 Size perforation *3/16 x 2 1/2*
 From *120* feet to *400* feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal *102* Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From *102* feet to *400* feet

9. WATER LEVEL
 Static water level *74.2* feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality *Good*

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name *Webber Drilling* Contractor
 Address *PO Box 40* Contractor
Overton Nv. 89040
 Nevada contractor's license number issued by the State Contractor's Board *0025887*
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller *2238*
 Signed *Brian Arvalone*
 By driller performing actual drilling on site or contractor
 Date *Feb. 11, 2008*

Date started *Dec 15*, 20*07*
 Date completed *Dec 30*, 20*07*

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<i>900</i>		<i>6 hrs</i>