

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33561

1. OWNER Tuffy Ranch Properties ADDRESS AT WELL LOCATION Geyser Ranch
MAILING ADDRESS 6609 N. Wingfield Parkway U.S. 93
Sparks Nv. 89436

2. LOCATION SW 1/4 SE 1/4 Sec. 1 T. 9 S. 65 E. Lincoln County
PERMIT NO. 15771 Issued by Water Resources Parcel No. 005 031 01 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Silt, Sand clay		0	12	12
Sand, gravel, cobbles		12	34	22
Clay		34	80	46
Sand, gravel		80	250	170
Clay		250	265	15
Silt, sand, gravel		265	480	215
Consolidated gravel		480	580	100
NAD 83				
38° 39' 57.25434				
114° 37' 44.68292				
N38.666016				
W 114.628334 NAD27				

8. WELL CONSTRUCTION

Depth Drilled 580 Feet Depth Cased 580 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>24</u>	<u>0</u>	<u>580</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>	<u>62.4</u>	<u>.375</u>	<u>0</u>	<u>580</u>

Perforations:

Type perforation Factory milled
Size perforation 3 1/8 x 2 1/2

From 140 feet to 580 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 115' Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 115 feet to 580 feet

9. WATER LEVEL

Static water level Flowing feet below land surface
Artesian flow 40 G.P.M. 2 P.S.I.
Water temperature 42 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Webber Drilling Contractor
Address PO Box 40 Contractor
Overton, Nv. 89040
Nevada contractor's license number issued by the State Contractor's Board 0025887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2238
Signed Bryan Anzabue
By driller performing actual drilling on site or contractor
Date July 20, 2008

Date started June 18, 2008
Date completed June 20, 2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>1500</u>		<u>6 hrs</u>