WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 106649
Permit No.
Basin 031

NOTICE OF INTENT NO. 62583

1. OWNER Bob Hoenck
MAILING ADDRESS 343 Bottle or. Rd
Winnemucca NV 89445
ADDRESS AT WELL LOCATION N 41.246449 W 118.303474 NAD27

2. LOCATION NE ¼ NW ¼ Sec. 20 T. 39 N/S R. 33 E. Humbolt County
PERMIT NO. 29131 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	
Gravel, Cobbles		10	30	
Sand and Brown clay		30	40	
Grey Clay		40	50	
Brow Clay, Sand Gravel		50	60	
Sand, Gravel, Cobbles		60	100	
Clay Sand Gravel		100	130	
Clean Gravel Cobbles		130	150	
Sand Gravel Cobbles Boulders		150	250	
Red Besalt, Cinders		250	290	
Red Cinder, Blue clay		290	310	
Blue Clay, Sand Gravel		310	360	
Hard Black Besalt		360	380	

Date started 7-14, 2008
Date completed 7-17, 2008

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

2008 AUG 22 AM 10:33

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
~~28~~	~~Inches~~	~~0 Feet~~	~~380 Feet~~
42	Inches	0 Feet	50 Feet
28	Inches	50 Feet	380 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		1/4	+1	380

Perforations:
Type perforation Double Row Millslot
Size perforation 1/4
From 80 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 0 feet to 380 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AMS Enterprises Contractor
Address 399 Denio Hy 140 Contractor
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0058683
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140
Signed Ralph Schad By driller performing actual drilling on site or contractor
Date 8-21-08

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627