STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106661
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62664

1. OWNER James Stauffer
MAILING ADDRESS 3340 E. Tallman - Winnemucca, NV

ADDRESS AT WELL LOCATION 3340 E. Tallman
Winnemucca, NV 89445
Subdivision Name: County: Humboldt

2. LOCATION SE ¼SE¼ Sec25T35N/ R37E
PERMIT/WAIVER NO. 014-154-04
Issued by Water Resources Parcel. No.

Latitude N40°87553 UTM E ☐ NAD 27
Longitude W117°75721 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Sand/gravel		135	136	1
hard clay		136	158	22
sand/gravel	X	158	170	12
Clay		170	175	5
gravel & sand	X	175	190	15
clays & gravel		190	220	30
cobles/gravel	X	220	235	15

2008 AUG 26 AM 11:00 STATE ENGINEER

N 40.875626
W 117.756247 NAD27

Date started: August 21, 20 08
Date completed: August 22, 20 08

9. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/4	Inches	135	Feet	235	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9	1.88	135	235

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32 X 4
From 195 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 126 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site of contractor
Date August 26, 2008