

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 106723  
Permit No. \_\_\_\_\_  
Basin Ø99

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62086

1. OWNER Mike Presser ADDRESS AT WELL LOCATION 180 Shetland Circle  
MAILING ADDRESS 180 Shetland Circle Reno, NV 89508  
Subdivision Name: \_\_\_\_\_ County: Washoe

2. LOCATION NE ¼ NE ¼ Sec 05 T 23N N/S R 18 E Latitude N 39.86470 UTM E  NAD 27  
PERMIT/WAIVER No. 16 | 078-161-17 Longitude W 119.96018 N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Granite Shelf T. D. 340 ft	x	240	340	100
<u>Deepening of log #50031</u>				
<u>#39.864794</u>				
<u>WAS 89148 NAD27</u>				
2008 AUG 14 AM 11:13 STATE ENGINEERS OFFICE				

9. WELL CONSTRUCTION

Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
6 1/8	240	340		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	10.79	188	220	340

Perforations:

Type of perforation	Factory
Size of perforation	3/32 X 3-
From _____ feet to _____ feet	
From 110 feet to 200 feet	
From 260 feet to 300 feet	
From 320 feet to 340 feet	

Annular Seal:  Yes  No

Neat Cement in place to \_\_\_\_\_  Pumped  Poured

Cement Grout to \_\_\_\_\_  Pumped  Poured

Concrete Grout to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Date started: 23-Jul 20 08  
Date completed: 30-Jul 20 08

7. Water Level  
Static water level: 50 feet below land surface  
Artesian Flow: N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
Water Temperature: Cold °F  
Quality: Clear

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	340	4 hrs
12	200	1 hr
12	150	1 hr

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service, LLC  
Contractor

Address P.O. Box 60130 Reno, NV 89506  
Contractor

Nevada contractor's license number issued by the State Contractor's Board 35387C

Nevada driller's license number issued by the Division of Water Resources 786

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 8/4/2008