STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106852
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33534

1. OWNER Trident Trust LP Partnership Downer Family
MAILING ADDRESS 30240 Rancho Viejo Rd #B San Juan Capistrano CA 92675
ADDRESS AT WELL LOCATION 4235 E Charleston Blvd Las Vegas, Nevada
Subdivision Name: County: Clark

2. LOCATION NW¼ NW¼ Sec 05 T 21 N OR 62 E
Latitude N 36° 09' 31.6" Longitude W 115° 04' 56.0"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. 16(-05-110-002 Issued by Water Resources
Parcel No. MW-10

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other 8" H.S. Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2" Asphalt & Base		0	1	1
Fill Silt Sand w/gr.		1	4	3
Silty Clay		4	6	2
Sandy Silt w/clay		6	9	3
Clayey Silt		9	12	3
Silty Sand	X	12	16	4
Sandy Clay		16	21	5
Silty Clay		21	25	4

Date started: 8-14, 20 08
Date completed: 8-14, 20 08

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Sch 40	F-480 PVC	0	25

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 10 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 8 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 9 to 25 ☐ Pumped ☒ Poured
Type: #3 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No 8 to 9 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug

7. Water Level
Static water level: 13.87 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA.	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 54931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1944
Signed Thomas M. Beall (By driller performing actual drilling on-site or contractor)
Date 9-4-08

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627