

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 106861
Permit No. _____
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34041

1. OWNER Big Daddy's Oil
MAILING ADDRESS 3230 E Flamingo Rd # 8-352
Las Vegas NV 89121

ADDRESS AT WELL LOCATION 3885 E charleston Blvd
MW-1B Las Vegas NV 89110
Subdivision Name: _____ County: Clark

2. LOCATION SW 1/4 SW 1/4 Sec 31 T 20 S N/S R 62 E
PERMIT/WAIVER No. 140-31-403-002
Issued by Water Resources Parcel No.

Latitude 36° 09' 55.4" UTM E NAD 27
Longitude 115° 05' 6.52" N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Ashphalt		0	.3	0
sand&large gravel		.3	3.5	3
brn si clay		3.5	6	3
tan silt	w/l/15	6	14	8
brown si clay		14	26	12
<div style="border: 2px solid black; padding: 5px; width: fit-content; margin: 0 auto;"> <p>DCNR/DWR RECEIVED OCT 15 2008 LAS VEGAS OFFICE</p> </div>				
FACILITY ID # <u>8-000953</u>				

9. WELL CONSTRUCTION

Depth Drilled	<u>26</u>	Feet	Depth Cased	<u>25</u>	Feet
HOLE DIAMETER (BIT SIZE)					
	From		To		
	<u>8</u>	Inches	<u>0</u>	Feet	<u>25</u> Feet
		Inches		Feet	Feet
		Inches		Feet	Feet
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
<u>4.5</u>	<u>10.79</u>	<u>.237</u>	<u>0</u>	<u>25</u>	

Perforations:
Type of perforation factory slotted
Size of perforation 0.02
From 10 feet to 25 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 8 to 25 Pumped Poured
Type: 10/20 Silica sand

Bentonite Chips: Yes No 1 to 8 Pumped Poured
Type: 3/8 Chips

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: n/a G.P.M. n/a P.S.I.
Water Temperature: n/a °F
Quality: good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>bailer</u>	<u>4</u>	<u>0</u>	<u>.5</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian way
Contractor
N Las Vegas NV 89030
Nevada contractor's license number 0012852
issued by the State Contractor's Board
Nevada driller's license number issued by the M-2371
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on site or contractor
Date 10-9-08