

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 107026  
Permit No. \_\_\_\_\_  
Basin 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62906

1. OWNER JORGE ALVAREZ ADDRESS AT WELL LOCATION 2553 NYE DR  
MAILING ADDRESS 2553 NYE DR MINDEN, NV 89423  
Subdivision Name: \_\_\_\_\_ County: Douglas

2. LOCATION NW 1/4 2 T 19N N/S R 20 E Latitude 39.02354°N UTM E  NAD 27  
PERMIT/WAIVER No. NW 1320-02-001-096 Longitude 119.70648°W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other ABANDONMENT

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PULLED OUT OLD PUMP				
CLEANED OUT TO BOTTOM				
240'				
OLD WELL WAS UNABLE TO BE DEEPEMED				
PERFORATED WELL FROM 105' TO 220'				
PLACED 1 1/2 TRIMMIE TO BOTTOM OF WELL AND PUMPED FULL OF NEAT CEMENT, HAD 25' FALL BACK TOPPED OFF DAY LATER				
USED 3.5 YRDS NEAT CEMENT				
<u>N39.023540</u>				
<u>W 119.706480</u>				

9. WELL CONSTRUCTION

Depth Drilled	Feet	Depth Cased	Feet
<u>N/A</u>		<u>240</u>	

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>N/A</u>			

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>+1</u>	<u>240</u>

Perforations:

Type of perforation	Size of perforation	From	To	Feet	Feet
<u>N/A</u>	<u>N/A</u>	<u>220</u>	<u>240</u>		

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured

Cement Grout N/A to N/A  Pumped  Poured

Concrete Grout to \_\_\_\_\_  Pumped  Poured

≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No N/A to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured

Type: \_\_\_\_\_

Date started: 28-Aug, 2008  
Date completed: 05-Sep, 2008

7. Water Level  
Static water level: 210 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COLD °F  
Quality: VERY POOR

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CAPTIAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor

Address # 20 KIT KAT DRIVE  
Contractor

CARSON CITY, NV 89706

Nevada contractor's license number issued by the State Contractor's Board 0055548

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905

Signed [Signature]  
By driller performing actual drilling on site of contractor

Date 09/18/2008

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEERS OFFICE  
2008 SEP 23 AM 10:52  
RECORDED