STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107039
Permit No.
Basin 179

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61732

1. OWNER Quadra-Robinson NV Mining V VD-08-07
MAILING ADDRESS P.O. Box 382
Ruth, NV 89319

ADDRESS AT WELL LOCATION Robinson Mine, 2 miles south of Ruth, NV
Subdivision Name: NA County: White Pine

2. LOCATION SW¼SE¼ Sec7T16N/ R62E
PERMIT/WAIVER NO. R-585 (Issued by Water Resources) NA (Parcel. No.)

Latitude 39.262541
Longitude 115.033102
UTM E 669697 ☒ NAD 27
N 4347547 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Quartz Manzanite		0'	420'	420'
Leached Quartz Manzanite		420'	460'	40'
Ely Marble		460'	765'	305'
Carbonaceous Limestone		765'	800'	35'

Note:
PVC plug set @ 260'
Neat Cement placed inside PVC from 260' to surface.

Date started: 14-Jun, 20 08
Date completed: 16-Jun, 20 08

9. WELL CONSTRUCTION
Depth Drilled 800 Feet Depth Cased 800 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8.750 Inches	0 Feet	18 Feet
6.750 Inches	18 Feet	800 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	.960	.218	+2	800

Perforations:
Type of perforation Slotted
Size of perforation .080
From 260 feet to 800 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0' to 220' ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 255' to 800' ☒ Pumped ☐ Poured
Type: #6 SRI
Bentonite Chips: ☒ Yes ☐ No 220' to 255' ☒ Pumped ☐ Poured
Type: 3/8 Hole Plug

7. Water Level
Static water level: 631 feet below land surface
Artesian Flow: G.P.M. P.S.I
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Drilling Services (CONTRACTOR)
Address P.O. Box 5279 (CONTRACTOR)
Elko, NV 89802
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2329
Signed
By driller performing actual drilling on site or contractor
Date 18-Jun-08

RECEIVED 2008 JUN 25 AM 11:43 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com