

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33512

1. OWNER ALBERT H. SMITH ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 346 DYER NV. 89010 EAGLE RD. + A STREET LOT 9
DYER NV. 89010
 2. LOCATION NE 1/4 Sec 32 T. 3 NOR 36 E ESMERALDA County
 PERMIT NO. 007-341-02 WHITE MOUNTAIN RANCH Subdivision Name
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other 4110

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY - BROWN		0	6	6
SANDY LOAM		6	22	16
SAND + GRAVEL		22	32	10
CLAY - BLUE		32	38	6
SAND + GRAVEL		38	62	24
CLAY - GRAVEL		62	92	30
GRAVEL	W.B	92	98	6
CLAY + GRAVEL		98	155	57
CLAY		155	170	15
SAND + GRAVEL	W.B	170	185	15
CLAY		185	195	10
SAND + GRAVEL	W.B	195	240	35

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 240 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>7.33</u>	<u>AC. SCH 40</u>	<u>0</u>	<u>240</u>

 Perforations:
 Type perforation FACTORY SCREEN
 Size perforation 0.32
 From 240 feet to 200 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 FT. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 240 feet to 50 feet

Date started 9-21, 2008
 Date completed 9-24, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 82 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____
 10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BUDGET DRILLING CO. Contractor
 Address P.O. Box 3505 Primm NV 89041 Contractor
 Nevada contractor's license number 40020 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 9-29-2008