STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107233
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33533

1. OWNER Trident Trust LP Partnership Downer Family
MAILING ADDRESS 30240 Rancho Viejo Rd #B San Juan Capistrano CA, 92625
ADDRESS AT WELL LOCATION 4235 E. Charleston Blvd Las Vegas, Nevada
Subdivision Name: County: Clark

2. LOCATION NW ¼ NW ¼ Sec 05 T 21 N/S R 62 E
Latitude N36° 09' 30.9" Longitude W 115° 09' 55.6"
UTM E N ☐ NAD 27 ☒ NAD 83/WGS 84
PERMIT/WAIVER No. 161-05-110-002 (Issued by Water Resources)
Parcel No. VRE-1

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other 10" HS Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
2" Asphalt / Base		0	1	1
Fill Silt Sand		1	3	2
Silty Clay		3	9	6
Clayey Silt		9	12	3

Date started: 8-11, 20 08
Date completed: 8-11, 20 08

7. Water Level
Static water level: NO Water feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	12	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Sch 40	ASTM F480 PVC	0	12

Perforations:
Type of perforation Factory Slots
Size of perforation 020
From 7 feet to 12 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 5 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 6 to 12 ☐ Pumped ☒ Poured
Type: #3 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No 5 to 6 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Elite Drilling Inc.
Address (Contractor) 4255 W. Post Rd. ~~Ste 4~~ Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 54431
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed (By driller performing actual drilling on-site or contractor) Thomas N. Beall
Date 9-4-08

USE ADDITIONAL SHEETS IF NECESSARY

DCNR/DWR RECEIVED NOV 20 2008 LAS VEGAS OFFICE

(Rev. 05-06)
(NSPO 3-08)
(O) 627