STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107267
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34034

1. OWNER trident trust lp
MAILING ADDRESS 21603 S E 416th St,
Enumclaw, WA, 98022-2000

ADDRESS AT WELL LOCATION 4325 E. Charleston Blvd
SB-14A Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION NW ¼ NW ¼ Sec 5 T 21S N/S R 62 E
PERMIT/WAIVER No. 161-05-102-006
Issued by Water Resources Parcel No.

Latitude 36.15882N
Longitude 115.07913W
UTM E
N
[X] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
type 2 fill		0	3	3
clay		3	8	5
silt		8	19	11
silty sand		19	25	6

DCNR/DWR
RECEIVED
SEP 29 2008
LAS VEGAS OFFICE

Date started: 22-Sep, 20 08
Date completed: 22-Sep, 20 08

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		sch 40	0	25

Perforations:
Type of perforation factory slotted
Size of perforation 0.02
From 8 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 6 to 23 [ ] Pumped [X] Poured
Type: 10-20 colorado silica sand
Bentonite Chips: [X] Yes [ ] No 1 to 6 [ ] Pumped [X] Poured
Type: medium bent. Chips

7. Water Level
Static water level: 11.7 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012-852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2057
Signed
By driller performing actual drilling on site or contractor
Date 9-29-08

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY