Amended

STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107451
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 63639

1. OWNER Rose Creek Ranch LLC
MAILING ADDRESS 9200 S. Beechcraft Boulevard
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION I-80 & Rose Creek Road
Well #3 - South Well
Subdivision Name: County: Humboldt

2. LOCATION NE ¼ SE ¼ Sec 24 T 35N N/S R 36 E
PERMIT/WAIVER No. 29816 (Issued by Water Resources) Parcel No.

Latitude 40'53.658 Longitude 117'52.247
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay with gravel layers | | 200 | 280 | 80 |
| N 40.894412 | | | | |
| W 117.869812 NAD27 | | | | |
| Deepening of log #15741 | | | | |

Date started: 30-Oct , 20
Date completed: 10/31/2008 , 20

9. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 14 | Inches | 200 | Feet | 280 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 14 | | .250 | 200 | 280 |
| | | | | |
| | | | | |

Perforations:
Type of perforation Mill-Slot
Size of perforation .90X3"
From 200 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

STATE ENGINEERS OFFICE
2008 NOV 25 AM 11:07
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources NV Inc dba Humboldt Drilling & Pump Co.Inc. (Contractor)
Address 4975 W. Winnemucca Boulevard (Contractor)
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the *State Contractor's Board* 56797
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1713
Signed Z. Tomkins - OFFICE (By driller performing actual drilling on site or contractor)
Date 11/22/2008

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY