1

STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107453
Permit No.
Basin Ø87

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63440

1. OWNER SFPP, L.P.
MAILING ADDRESS 1100 Town & Country Rd. Orange CA 92868

ADDRESS AT WELL LOCATION 333 Galletti Way Reno, NV 89512
Subdivision Name: County: Washoe

2. LOCATION NE ¼ NW ¼ Sec 7 T 19 N/S R 20 E
PERMIT/WAIVER No. D-00762 1229305
Issued by Water Resources Parcel No.

Latitude 3932056 UTM E ☐ NAD 27
Longitude 11946842 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Sonic

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand, gravels & boulders | | 0 | 35 | 35 |
| Same material | X | 35 | 65 | 30 |
| N39.534376 | | | | |
| W119.779695 NAD27 | | | | |

Date started: 10-19, 20 08
Date completed: 10-19, 20 08

9. WELL CONSTRUCTION
Depth Drilled 66 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 8 | Inches | 0 | Feet | 66 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4 | | Schd 40 PVC | 0 | 65 |

Perforations:
Type of perforation PVC screen
Size of perforation 0.20
From 30 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 25 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 28 to 66 ☐ Pumped ☒ Poured
Type: #3 Monterey
Bentonite Chips: ☒ Yes ☐ No 25 to 28 ☐ Pumped ☒ Poured
Type: 3/8 Hole plug

7. Water Level
Static water level: 33 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

STATE ENGINEERS OFFICE
2008 NOV 24 AM 11:50
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear
Contractor
Address 3894 Railroad Ave
Contractor
Yuba City, CA 95991
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2234
Signed [signature]
By driller performing actual drilling on-site or contractor
Date 11-12-08

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627