

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61753

1. OWNER Jerry Dunbar ADDRESS AT WELL LOCATION Approx. 70 miles East of Ely, NV along Hwy. 6 & 50
 MAILING ADDRESS POB 430 N39.070919 W114.164325 NAD83
Chino Valley, AZ 86323
 2. LOCATION NW 1/4 SW 1/4 Sec 19 T 14 N R 70 E White Pine County
 PERMIT NO. 012-810-03 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Gravel		2	11	9
Brown Clay		11	13	2
Boulders		13	25	12
Clay & Gravel		25	27	2
Quartz Boulders		27	40	13
Clay Boulders		40	50	10
Brown Clay		50	65	15
Clay & Course Gravel	x	65	70	5
Brown Clay & Gravel		70	105	35
Small Gravel		105	110	5
Gray Clay		110	170	60
Sand, Gravel, & Clay	x	170	178	8
Brown Clay		178	250	72
Clay & Sm. Gravel	x	250	255	5
Brown Clay		255	310	55
Blue Clay w/ Sand & Gravel Strings	x	310	322	12
Blue Clay		322	360	38
Brown Clay		360	495	135
Brown Clay & Rock		495	570	75
Brown Clay		570	610	40
Sand & Course Gravel	x	610	635	25
Grey Clay		635	660	25

WGS 84
 Lat. N39° 04', 15.1"
 Long. W114° 09', 54.6"
 Elev. 5,542'

8. WELL CONSTRUCTION
 Depth Drilled 660 Feet Depth Cascd 660 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 660
12 3/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	660

Perforations: Factory
 Type perforation _____
 Size perforation 1/8 x 2 1/2 8 Rows
 From 155 feet to 195 feet
 From 215 feet to 235 feet
 From 315 feet to 355 feet
 From 495 feet to 535 feet
 From 595 feet to 655 feet
 Surface Seal: Yes No 655 - 660 Blank
 Depth of Seal 50' Seal Type: Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 660 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Ave. Contractor
Ely, NV 89301
 Nevada contractor's license number 14790 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793 Division of Water Resources, the on-site driller
 Signed Richard Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date November 24, 2008

Date started September 3, 2008
 Date completed October 28, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
Air	750	114	2
20 H.P. Submers	200	114	4