WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 107709
Permit No. 73348
Basin 212

NOTICE OF INTENT NO. 34744

1. OWNER DAVIS BROS INVESTMENTS LLC
MAILING ADDRESS 7210 PLACID ST.
LV. NV. 89119
ADDRESS AT WELL LOCATION 14355 DIXON ST
LV. NV.

2. LOCATION NE ¼ SW ¼ Sec. 19 T 23 S N/S R 61 E CLARK County
PERMIT NO. 73348 (Issued by Water Resources) 191-19-301-006 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☑ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	32'	32
Cement Gravel		32	140'	
Brown Clay		140	145	
Volcanic		145	280	
Clay + Gravel		280	460	
Brown Clay		460	500	
Volcanic		500	780	
Quartz		780	890	
Sand Stone + Water		890	920	
Red Clay		920	950	
White Quartz Sand		950	1020	
Lime Stone & Water		1020	1140	
Caving Lime Stone		1140	1200	
35.931246°N				
115.199895°W NAD27				
N35° 55' 52.4 — NAD 27				
W15° 12' 02.6				

DCNR/DWR
RECEIVED
FEB 25 2009
LAS VEGAS OFFICE

Date started 07-08-08, 20
Date complated 02-19-09, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1200 Feet Depth Cased 1140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	810 Feet
7⅞ Inches	810 Feet	1200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.97	.188	+1	810
6 5/8	12.00	.188	700	1140
	12			

Perforations:
Type perforation Torch
Size perforation ¼ x 6" 4 times around
From 1040 feet to 1140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 810
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 471 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature WARM °F Quality

2009 JUN 19 AM 8:35

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name V. H. Dimick (Contractor)
Address 5360 N. BONITA VISTA ST (Contractor)
LV. NV. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 02-25-09

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627