STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107736
Permit No.
Basin Ø89

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62915

1. OWNER LISA LETARTI
MAILING ADDRESS P.O. BOX 22711
NW CARSON CITY, NV 89721

ADDRESS AT WELL LOCATION 3560 NYE DR
WASHOE CITY, NV 89704
Subdivision Name: County: Washoe

2. LOCATION SW ¼ NE ¼ Sec 6 T 16N N/S R 20 E
PERMIT/WAIVER No. SE 050-462-21
Issued by Water Resources Parcel No.

Latitude 39.28083°N UTM E ☐ NAD 27
Longitude 119.77983°W N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
DG SANDS		3	16	13
GRAY SILTY SANDS		16	89	73
GRAY CLAY		89	138	49
GRAY SILTY SANDS W/CLAY	XXX	138	180	42

N39.280920
W119.77983 NAD27

Date started: 06-Oct, 20 08
Date completed: 08-Oct, 20 08

7. Water Level
Static water level: 60' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 180' Feet Depth Cased 180' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	180

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3X3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 100 to 180 ☐ Pumped ☒ Poured
Type: PEAT GRAVLEL
Bentonite Chips: ☐ Yes ☐ No X to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed Michael F Hack
By driller performing actual drilling on site or contractor
Date 10/18/2008

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2008 NOV -4 AM 11:19
STATE ENGINEERS OFFICE