

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY **107737**

Log No. \_\_\_\_\_  
Permit No. \_\_\_\_\_  
Basin **107**

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. **62911**

**1 OWNER ERIC PETERSON**  
MAILING ADDRESS **# 61 CARTER LN  
SMITH VALLEY NV 89444**

ADDRESS AT WELL LOCATION **25 FOOTHILL RD  
SMITH VALLEY NV 89444**  
Subdivision Name: \_\_\_\_\_ County: **Washoe LYON**

**2 LOCATION SW 1/4 SE 1/4 Sec 20 T 11N N/S/R 24 E**  
PERMIT/WAIVER No. **010-522-01**  
Issued by Water Resources Parcel No.

Latitude **38.79822°N** UTM E  NAD 27  
Longitude **119.31924°W** N  NAD 83/WGS 84

**3 TYPE OF WELL**  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? **YES**  
If yes, what is replacement well NOI? **62910**

Is there an existing well log? **yes**  
If yes, what is NDWR well log #? **15308**

**4 EXISTING WELL CONSTRUCTION**  
Depth Drilled **96** Feet Depth Cased **96** Feet

**7 WELL PLUGGING PROCEDURE**  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

**EXISTING CASING SCHEDULE**

Size O.D. (Inches)	Weight/FL (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.34	.188	+2	96

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

**Existing Perforations:**

Type of perforation	Size of perforation	From	feet to	feet
SLOTTED	76	From	feet to	96 feet
		From	feet to	
		From	feet to	
		From	feet to	
		From	feet to	

**Additional Perforations:**

Type of perforator used:	From	feet to	feet	Number of perfs per linear foot
MILLS KNIFE	From 45	feet to 75	feet	6
	From	feet to	feet	
	From	feet to	feet	
	From	feet to	feet	
	From	feet to	feet	
	From	feet to	feet	

**5 WATER LEVEL**  
Static water level **89'** feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature **N/A** °F Quality **BAD**

**8 WELL PLUGGING MATERIALS**

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
From 0	feet to 96	feet	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>
From	feet to	feet		<input type="checkbox"/>	<input type="checkbox"/>

**6 Additional Notes or Comments**

**PULLED OUT OLD PUMP, TAGGED BOTTOM OF WELL TO 96' PERFORATED WELL FROM ABOUT 45 TO 75'**  
**TRIMIE PIPE TO BOTTOM OF WELL AND PUMPED FULL OF NEAT CEMENT, 3 1/2 - 4 YRDS CEMENT FELL BACK ABOUT 15 FT TOPPED OPFF WITH CEMENT SAND SLURRY**

Neat Cement Fluid Weight **94/4** lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite  
Date Started **10/29/2008**  
Date Completed **10/31/2008**

**N36.798308**  
**W 119.319248 NAD27**  
**STATE ENGINEERS OFFICE**  
**NOV 6 AM 11-03**

**9 DRILLER'S CERTIFICATION**  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name **CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.** Contractor  
Address **# 20 KIT KAT DRIVE** Contractor  
**CARSON CITY NV 89706**  
Nevada contractor's license number issued by the State Contractor's Board **0055548**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**  
Signed **Michael Had** My driller performing actual drilling on-site or contractor  
Date **11/02/2008**