STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 107756
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33677

1. OWNER Eastern Plaza Investment LLC
MAILING ADDRESS 1244 E 8th St
Los Angeles, CA, 90021

ADDRESS AT WELL LOCATION 5025 S Eastern Ave
MW-6 Las Vegas, NV, 89119
Subdivision Name: County: Clark

2. LOCATION SE ¼ NE ¼ Sec 26 T 21S N/S R 61 E
PERMIT/WAIVER No. MO-2825 (Issued by Water Resources) 162-26-506-009 Parcel No.
Latitude 36. 05842 Longitude 115. 07113
UTM E N [X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey Sand		0	4	4
Caliche		4	5	1
Sandy Clay	x	5	11	6
Caliche		11	14	3
Sandy Clay		14	18	4
Fat Clay		18	19	1
Sandy Clay		19	20	1

Date started: 2-Apr , 20 09
Date completed: 2-Apr , 20 09

9. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	20	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	3.65	.154	0	20

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 3 to 20 [ ] Pumped [X] Poured
Type: #3 Montery Sand
Bentonite Chips: [X] Yes [ ] No 1 to 3 [ ] Pumped [X] Poured
Type: 3/8 Medium bent Chips

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	0	.5

DCNR/DWR RECEIVED
APR 21 2009
LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells (Contractor)
Address 570 Corinthian Way (Contractor)
N. Las Vegas, NV, 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed (By driller performing actual drilling on site or contractor)
Date 4-21-09

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY